

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2635 / जल परीक्षण / 58

Dated: 12/06/2025

It is certified that an inspection team headed by Saurabh Kumar (Lab chemist)

(Name of Officers with designation) from U.P. Jal Nigam (rural) Mainpuri


(Name of Department/ Office) inspected the International Delhi Public School

(Name & Address of the school) on 12/06/25 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 11/06/2026

Signature with Seal: 

Name : Rohitendra Kumar

Designation : Assistant Engineer

Assistant Engineer of Divisional Office UPJN (Rural)
the Govt. Public Health Department (PHED)
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

International Delhi public School
Sirsaganj Road, Dhowai Kothal Mainpuri

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Analysis Report

District Level Water Analysis Laboratory U.P. Jal Nigam(Rural), Mainpuri.

Report No.	767	Date : 12/06/2025	Page No. 1
Office Name and Address	Customer Details		
Ref Letter No. & Date	International Delhi Public School, Sirsaganj Road, Dhobai, Karhal, Mainpuri		
	00, 10/06/2025		

Basic details of sample

Address	International Delhi Public School, Sirsaganj Road, Dhobai, Karhal, Mainpuri		
Water Source	Tubewell	Sample No.	Pvt 857320
Quantity of Sample	1 lt.	Date of Sample Collection Date	11/06/2025
Receiving Date	11/06/2025	Sample Collector	Vijay Pratap
Sample Depositer	DEO	Sampling Method	IS: 17614 (part-1) : 2021
Analysis Start Date	11/06/2025	Analysis Completion Date	12/06/2025

Technical Data of Analysis

Sr. No.	Analysis Parameter	Units	Observed Value	Specified Values as per BIS 10500:2021		Ref.Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	Hazen	0	5	15	IS 3025(Part 4):2023(Platinum Cobalt Visual Comparison Methode)
2	pH	-	7.94	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022 (Electrometric Method)
3	Turbidity	(NTU)	1.820	1.00	5.00	IS 3025 (Part 10): 2023(Nephelometric Mathod)
4	TDS	(mg/L)	505.7	500	2000	IS 3025 (Part 16): 2023(Gravimetric Mathod)
5	Chloride	(mg/L)	67.99	250	1000	IS 3025 (Part 32): 2019 (Argentometric Method)
6	Total Alkalinity	(mg/L)	360	200	600	IS 3025 (Part 23): 2023 (Indicator Mathod)
7	Total Hardness	(mg/L)	326	200	600	IS 3025(Part 21):2019 (EDTA Mathod)
8	Sulphate	(mg/L)	17.83	200	400	APHA 24th Edition -4500-SO4 Method F : 2023
9	Calcium	(mg/L)	44.68	75	200	IS 3025(Part 40):2023(EDTA Titrimetric Mathod)
10	Magnesium	(mg/L)	44.51	30	100	IS 3025(Part46):2023
11	Iron	(mg/L)	0.29	0.3	1.0	APHA 24th Edition – 3500-Fe Method B (Phenanthroline Method):2023
12	Nitrate	(mg/L)	18.50	45	No Relaxation	APHA 24th Edition -4500- NO3 Method B (UV Screening Method): 2023

- Note:-
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of laboratory.
 3. The Test result reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.

Prepared By

Hitesh Kumar
Deputy Quality Manager

Result approved by

